


FRI 400 – FRI 600 MODULAR TIME SWITCH

FOR INDUSTRIAL COOLING

INSTRUCTIONS FOR USE



INSTALLATION


DIN rail or base mounting.


CONNECTION

As diagram:









PROGRAMMING

24 hours dial: Minute dial: Start of operation and open C1 and C4. Close C2. Adjust for duration, first pin open C2. Second pin closes C4 (FRI 600), or reset a new cycle (FRI 400). Maximum pins acceptable on minute dial: two.

TO SET HOUR

Turn the minute dial in the direction of the arrow. Note that the time on the daily dial and minute dial must coincide with index.

WARNING: NEVER TURN THE 24 HOURS DIAL.

MINIMUM OPERATION


Minute dial:


5 to 50 minutes.

PRECAUTION

Do not place two consecutive pins on the 24 hours dial (2 hours minimum). Colour of each pin must coincide with dial colour.

DIMENSIONS







A016.15.37756 ORBIS TECNOLOGÍA ELÉCTRICA, S.A. Lérida, 61 E–28020 MADRID Teléfono:+ 34 91 5672277; Fax:+34 91 5714006 E-mail: <u>info@orbis.es</u> <u>http://www.orbis.es</u>